LISTING SERVICE

LISTING No. 7271-1496:120 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Firecom Inc., 39-27 59th Street, Woodside, NY 11377
Contact: Howard Kogen (718) 899-6100 FAX (718) 899-1932

DESIGN: Model F900-550 ionization type smoke detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 17 - 28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as ionization smoke detector for use with listee's Models F900-MB-6, F900-MB-6LP or F900-MB-6RLY (CSFM Listing No. 7300-1496:128) mounting base and separately listed compatible fire alarm control units.

XLF: 7271-1394:103

02-19-98

Date Issued: **JUNE 22, 2004** *Listing Expires* **June 30, 2005**

Authorized By: *DIANE K. AREND, Senior Deputy Program Manager*